



EDWARD M. BIRN  
Director (Direktot)

BERNADINE C. GINES  
Deputy Director (Sigundo Direktot)

# DEPARTMENT OF ADMINISTRATION

DIPATTAMENTON ATMENESTRASION

GENERAL SERVICES AGENCY

(Ahensian Setbision Hinirat)

Telephone (Telifon): (671) 475-1707/1729 • Fax (Faks): (671) 472-4217/1727



LOURDES A. LEON GUERRERO  
Governor (Maga'håga)

JOSHUA F. TENORIO  
Lt. Governor (Sigundo Maga'låhi)

September 01, 2021

## INVITATION FOR BID

GSA-053-21

REMOVAL AND INSTALLATION OF A NEW GENERATOR WITH PAD  
AND AUTOMATIC TRANSFER SWITCH

### AMENDMENT #2

1. Amend to change on page 34 of 35 under "SPECIFICATIONS" the following:

From:

The following are New Generator Unit Specifications:

Provide and install a commercial type one (1) 250 KVA 3ph-208v-60hz Generator Set with an Automatic Transfer Switch including weather protective enclosure with silencer, set mounted battery charger, double wall sub-tank with three (3) days capacity, conduit, electrical wires and should be certified by a licensed master electrician.

To Now Read:

The following are New Generator Unit Specifications:

Provide and install a commercial type one (1) **150 KVA** 3ph-208v-60hz Generator Set with an Automatic Transfer Switch including weather protective enclosure with silencer, set mounted battery charger, double wall sub-tank with three (3) days capacity, conduit, electrical wires and should be certified by a licensed master electrician.

All others remain unchanged.

  
CLAUDIA S. ACFALLE  
Chief Procurement Officer

Please Print

ACKNOWLEDGEMENT COPY (Re-fax to GSA)

Received By: \_\_\_\_\_

Date: \_\_\_\_\_

Company Name: \_\_\_\_\_

Fax to: 475-1727 or 472-4217

E-mail to: [gsaprocurement@gsadoa.guam.gov](mailto:gsaprocurement@gsadoa.guam.gov)